

**DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAII**

345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAII 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657


November 14, 2013

**TO:** HOLDERS OF WATER SYSTEM STANDARDS 2002  
**FROM:** Quirino Antonio, Jr., Manager-Chief Engineer  
**SUBJECT: WATER SYSTEM STANDARDS  
AMENDMENT NO. 6**

Please insert the enclosed document in your publication of the subject Water System Standards, which you received from this office.

If you have any questions, please contact Mr. Kurt Inaba, Engineering Division Head, at (808) 961-8070.


Sincerely yours,

  
Quirino Antonio, Jr., P.E.  
Manager-Chief Engineer

ON:dmj

Enc.

copy - Board of Water Supply, City and County of Honolulu  
Department of Water Supply, County of Maui  
Department of Water Supply, County of Kauai



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAII

345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAII 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657

November 14, 2013

TO: ALL CONCERNED  
FROM: QUIRINO ANTONIO, JR., MANAGER-CHIEF ENGINEER  
SUBJECT: AMENDMENT NO. 6 TO THE 2002 WATER SYSTEM STANDARDS

The following revisions shall be made to the 2002 Water System Standards:

**1. Division 200, Section 211 – Brass Products**

Effective January 4, 2014, the following specification shall be **added** to Subsection 211.01 – General:

**“For Hawaii only: All Brass Products shall conform to Section 1417 of the Safe Drinking Water Act (SDWA) and shall have lead contents of a weighted average of not more than 0.25% in the wetted surface material. In addition to NSF Standard 61, all Brass Products shall conform to NSF Standard 372.”**

END

BY AUTHORITY OF THE DEPARTMENT OF WATER SUPPLY  
COUNTY OF HAWAII

By \_\_\_\_\_

Manager-Chief Engineer

Effective Date of Amendment: November 14, 2013