



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAI'I 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY
COUNTY OF HAWAI'I
HILO, HAWAI'I

ADDENDUM NO. 1

JOB NO. 2019-1109

INVITATION FOR BIDS
FOR THE

**‘ŌLA‘A #3 CHLORINATION SYSTEM REPLACEMENT
DISTRICT OF PUNA
County of Hawai‘i – State of Hawai‘i**

The following revisions and changes shall be made a part of the contract bidding documents:

CLARIFICATIONS:

- a. The discharge pressure of the tablet chlorination system should be designed for 5 – 10 psi above the tablet chlorination system supply pressure.
- b. The supply pressure for the tablet chlorination system is expected to be in the range of 107 – 145 psi.
- c. The tablet chlorination system should be designed for 120V, 1 phase.
- d. The pump model for the tablet chlorination system shall be determined by the system manufacturer based upon the specific site operating conditions.
- e. The “Gate Valve” identified in Section 304.05 B.3.h. of the Special Provisions is correctly identified as a gate valve, and not a diaphragm valve.
- f. As part of Part “A”, Item 4, of the Official Proposal, the Contractor is to furnish the chlorine residual analyzer that is to be installed.

BY AUTHORITY OF THE DEPARTMENT OF
WATER SUPPLY COUNTY OF HAWAI'I

Date: October 8, 2020

By: 
Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 1** for JOB NO. 2019-1109, INVITATION FOR BIDS FOR THE ‘ŌLA‘A #3 CHLORINATION SYSTEM REPLACEMENT, District of Puna, County of Hawai‘i, State of Hawai‘i, is hereby acknowledged.

NAME OF BIDDER

Date: _____

By: _____

...Water, Our Most Precious Resource...Ka Wai A Kāne...

The Department of Water Supply is an Equal Opportunity provider and employer.