



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I
345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAI'I 96720
TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY
COUNTY OF HAWAI'I
HILO, HAWAI'I

ADDENDUM NO. 2

JOB NO. 2019-1105

INVITATION FOR BIDS
FOR THE

KA'AUHUHU #2 BOOSTERS A, B & C REPAIR
DISTRICT OF NORTH KOHALA
County of Hawai'i – State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

1. Changes to **PROPOSAL:**

- a. **DELETE** Proposal section its entirety and **REPLACE** with the attached replacement Proposal Section.
 - i. Revisions have been made to the following pages:
 - (1) Page P-9, replaced with page P-9A, revises Part "C" (Materials & Services), Item No. 8. Booster assembly vibration peak velocity of 0.05 ips has been increased to *0.156 ips*.
 - (2) Page P-10, replaced with page P-10A, revises Part "D" (Electrical Work), Item No. 3. Change includes the addition of a third heavy duty safety switch for booster C and the revision of the specified switch amperage rating for all three heavy duty safety switches.

2. Changes to **SPECIAL PROVISIONS:**

- a. **REVISE** Page SP-10, Section 304.03 A.3.c., the existing language for this item shall be deleted in its entirety and replaced with the following:

"Installation of three (3) NEMA 3R painted steel heavy duty safety switches, conduit, and new wire to provide power to three (3) motors for Boosters A, B & C, inclusive of mounting hardware. Safety switches shall be wall mounted or supported by galvanized steel Unistrut mounting structures with stainless steel fasteners at the option of the Contractor.
- b. **REVISE** Page SP-35, Section 304.05 A.4.h., booster assembly vibration peak velocity of 0.05 ips shall be increased to *0.156 ips*.
- c. **REVISE** Page SP-43, Section 304.05 B.7.d., Krohne model Waterflux 3070 C flow meter body material shall be changed from stainless steel to *coated carbon steel*.

...Water, Our Most Precious Resource ...Ka Wai A Kāne...

The Department of Water Supply is an Equal Opportunity provider and employer.

- d. **REVISE** Page SP-44, Section 304.05 C.1.c., the existing language for this item shall be deleted in its entirety and replaced with the following:

“The Contractor shall repair the boosters in sequence and complete a satisfactory efficiency test before starting on the repair of the next booster. Booster C shall be the first booster repaired with boosters A & B repair sequence to be coordinated with DWS personnel. Prior to taking any booster offline, all materials required to replace the booster shall be onsite or staged at the Contractors baseyard to minimize downtime.”

BY AUTHORITY OF THE DEPARTMENT OF
WATER SUPPLY COUNTY OF HAWAI'I

Date: October 30, 2020

By: 
Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 2** for JOB NO. 2019-1105, INVITATION FOR BIDS FOR THE KA'AUHUUHU #2 BOOSTERS A, B & C REPAIR, District of North Kohala, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

NAME OF BIDDER

Date: _____

By: _____