



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI`I

345 KEKŪANAŌ`A STREET, SUITE 20 • HILO, HAWAI`I 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY
COUNTY OF HAWAI`I
HILO, HAWAI`I

ADDENDUM NO. 1

JOB NO. 2022-1204

INVITATION FOR BIDS

FOR THE

HUALĀLAI DEEPWELL REPAIR

DISTRICT OF NORTH KONA

County of Hawai`i – State of Hawai`i

The following revisions and changes shall be made a part of the contract bidding documents:

A) Changes to **PROPOSAL**:

- a) **DELETE** in its entirety and **REPLACE** with the attached revised Proposal. Changes to Proposal include the following:
 - 1) Page P-8A, **ADD** line item for Pump Warranty Cost.
 - 2) Page P-9A, **REVISE** Motor description and the “Motor Warranty Cost” line item. **DELETE** the “Cost for Sensor Refurbishment” from breakdown cost.
- b) Page P-7A – P-8A, Part D, **CLARIFY** the following:
 - 1) The refurbishment allowance of \$20,000.00 for each item in Part “D” is intended to cover the cost of replacement parts, as needed, to repair the equipment as is determined by the teardown report. The charge to be paid for the replacement parts will be determined by the prices the bidder lists in the items labeled ‘(NOT SUMMED IN TOTAL LUMP SUM BID)’. Per the Special Provisions Section 304.05.B.13.a, providing a breakdown cost is required.
 - 2) If it is found through the teardown that the cost of replacement parts will exceed the \$20,000.00 allowance, the Contractor shall pursue a Change Order at that time with the appropriate justification.
 - 3) Costs associated with the teardown, inspection, assembly, and warranty, that are established before evaluating the condition of the equipment shall be included in the ‘TEARDOWN, INSPECTION & ASSEMBLE COST’ line item.

...Water, Our Most Precious Resource...Ka Wai A Kāne...

The Department of Water Supply is an Equal Opportunity provider and employer.

- 4) Costs associated with providing 1-year Contractor warranty on the equipment shall be included in the equipment's respective 'WARRANTY COST' line item.

B) Changes to **SPECIAL PROVISIONS**:

- a) Page SP-17, Section 304.05.A.5.c.i.a), **CLARIFY** the following:
 - 1) The awarded Contractor shall be responsible for arranging a licensed professional engineer (P.E.) to witness testing.
- b) Page SP-51 – SP-52, Section 304.05.B.13.e. **DELETE** "Motor Sensor Refurbishment" in its entirety.

BY AUTHORITY OF THE DEPARTMENT OF
WATER SUPPLY COUNTY OF HAWAI'I

Date: January 5, 2023

By: 
Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 1** for JOB NO. 2022-1204, HUALĀLAI DEEPWELL REPAIR, District of North Kona, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

NAME OF BIDDER

Date: _____

By: _____