

## **DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I**

345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAI'I 96720 TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I HILO, HAWAI'I

ADDENDUM NO. 2

JOB NO. 2023-1234

**INVITATION FOR BIDS** 

FOR THE

PANA'EWA WELLS A& B REPAIR

DISTRICT OF SOUTH HILO County of Hawai'i – State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

## I. CLARIFICATIONS:

- A. The existing combination couplings are generally in good condition. Refurbishment is to address the existing surface corrosion and to prevent future corrosion. Work would require subcontracting to multiple vendors to clean and machine the combination couplings to meet tolerances; coat the combination couplings, then outfit with new bearings.
- B. Application services for the NSF-61 approved polyamide 11 coating, Arkema Rilsan® Fine Powders T Black 7239 MAC specified within the bid documents can be obtained from Crest Coating, Inc., 1-888-709-2760, 1361 S. Allec St., Anaheim, CA 92805; Fisher Company, 1-801-298-2570, 955 N. Main St., North Salt Lake, UT 84054; Coating Systems, Inc., 1-513-367-5600, 150 Sales Ave., Harrison, OH 45030; or others.

BY AUTHORITY OF THE DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I

Date: August 6, 2025

By: Keith K. Okamoto, P. E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of ADDENDUM NO. 2 for JOB NO. 2023-1234, INVITATION FOR BIDS FOR THE PANA'EWA WELLS A & B REPAIR, District of South Hilo, County of Hawai'i, State of Hawai'i, is hereby

acknowledged.

	<del></del>
	NAME OF BIDDER
Date:	Ву: