

## **DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I**

345 KEKŪANAŌʻA STREET, SUITE 20 • HILO, HAWAIʻI 96720 TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I HILO, HAWAI'I

## **ADDENDUM NO. 3**

MATERIAL BID NO. 2025-05

**INVITATION FOR BIDS** 

FURNISHING AND DELIVERING SPARE PUMP AND MOTOR SETS AND PAD-MOUNTED TRANSFORMERS

DISTRICTS ISLANDWIDE County of Hawai'i – State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

i. Changes to be ECIAL FRO VIDIO 145	I.	Changes to	<b>SPECIAL</b>	<b>PROVISIONS</b>
--------------------------------------	----	------------	----------------	-------------------

A. SP-9 **REVISE**, Section 304.05, Part A.5.d.i.a.i), the existing language shall be revised as follows:

"The required pump test acceptance grade exceeds all grades listed under ANSI/HI 14.6. Corresponding tolerance band shall be as follows:

1 1

a)) Rate of flow: -0% to +5%

b)) Total head: -0% to +3%

c)) Efficiency: -0%"

BY AUTHORITY OF THE DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I

N

Date:	August 4, 2025	By: Keith K. Okamoto, P.E., Manager-Chief Engineer
		Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 3** for MATERIAL BID NO. 2025-05, INVITATION FOR BIDS FURNISHING AND DELIVERING SPARE PUMP AND MOTOR SETS AND PAD-MOUNTED TRANSFORMERS, Districts Islandwide, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

	NAME OF BIDDER
Date:	Ву: