



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAO'A STREET, SUITE 20 • HILO, HAWAI'I 96720
TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY
COUNTY OF HAWAI'I
HILO, HAWAI'I

ADDENDUM NO. 1

MATERIAL BID NO. 2025-17

INVITATION FOR BIDS

FURNISHING AND DELIVERING
REPLACEMENT 0.040 MG STEEL RESERVOIRS

DISTRICT OF NORTH KOHALA
County of Hawai'i – State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

I. CLARIFICATION:

A. A total of eight (8) 6" tank flanges shall be provided, four (4) per reservoir.

II. Changes to **PROPOSAL**:

A. Page P-3, **REVISE** Proposal, Part A description shall change thickness of roof panels from 14 ga. to 22 ga.

B. Page P-3, **REVISE** Proposal, Part A description shall change thickness of potable water liner (NSF-61) from 40 mil to 30 mil.

C. Page P-3, **REVISE** Proposal, Part A description shall change quantity of tank flanges from eight (8) to four (4).

III. Changes to **SPECIAL PROVISIONS**:

A. Page SP-4, **REVISE**, Section 221200 Part 2.08, the thickness of the flexible membrane liner shall be changed from 40 mil to 30 mil.

BY AUTHORITY OF THE DEPARTMENT OF
WATER SUPPLY COUNTY OF HAWAI'I

Date: September 8, 2025

By: 
Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 1** for MATERIAL BID NO. 2025-17, INVITATION FOR BIDS
FURNISHING AND DELIVERING REPLACEMENT 0.040 MG STEEL RESERVOIRS, District of North
Kohala, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

NAME OF BIDDER

Date: _____

By: _____