



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAO'A STREET, SUITE 20 • HILO, HAWAI'I 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY
COUNTY OF HAWAI'I
HILO, HAWAI'I

ADDENDUM NO. 1

SERVICE BID NO. 2025-20

INVITATION FOR BIDS

FOR THE

FURNISHING AND DELIVERING
WAIMEA WATER TREATMENT PLANT
RAW WATER VALVE

DISTRICT SOUTH KOHALA
County of Hawai'i – State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

I. Changes to **SPECIAL PROVISIONS:**

- Page SP-2, **REVISE** Part B.3.b., shall be revised to:
 - “The valve shaft shall be of 2205 duplex stainless steel ASTM A564 or 17-4PH H1150M stainless steel ASTM A564, keyed on outboard end, and bearings shall be PTFE lined fiberglass.”

BY AUTHORITY OF THE DEPARTMENT OF
WATER SUPPLY COUNTY OF HAWAI'I

Date: November 14, 2025

By: 
Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 1** for SERVICE BID NO. 2025-20, INVITATION FOR BIDS FOR THE F&D WAIMEA WATER TREATMENT PLANT RAW WATER VALVE, District South Kohala, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

NAME OF BIDDER

Date: _____

By: _____

... Water, Our Most Precious Resource ... Ka Wai A Kāne ...

The Department of Water Supply is an Equal Opportunity provider and employer.