

DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAŌʻA STREET, SUITE 20 • HILO, HAWAIʻI 96720 TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I HILO, HAWAI'I

ADDENDUM NO. 2

MATERIAL BID NO. 2025-20 INVITATION FOR BIDS

FOR THE

FURNISHING AND DELIVERING WAIMEA WATER TREATMENT PLANT RAW WATER VALVE

DISTRICT SOUTH KOHALA County of Hawai'i – State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

I. Changes to **INSTRUCTION TO BIDDERS**:

o Pages IB-14 to IB-15, <u>DELETE</u>, requirements in reference to Title 33 U.S.C. §3914 and CFR Title 40 §35.10030 "American Iron & Steel", and P.L. 117-58, §§ 70901-52, "Build America, Buy America" Act.

II. Changes to PROPOSAL:

- o Page P-2, <u>REVISE</u> "Major Material Cost Items (As Needed)" Item No. 1 Description, shall be revised to:
 - "DeZurik BHP-6-L1-S2-TC-S2-S10B-FT-TT High Performance Butterfly Valve, <u>Bray McCannalok Series 4A-0600-11001-066 High Performance Butterfly Valve</u>, or equal by approval, 6—inch Class 150# <u>double flanged or lugged type with unthreaded through holes if double flanged is unavailable</u>, 316 stainless steel body, PTFE V-Flex packing, 316 stainless steel disc, 17-4PH stainless steel shaft, PTFE fabric bearing and seat seal with surface freight included."

III. Changes to **SPECIAL PROVISIONS**:

o <u>REPLACE</u> pages SP-2 to SP-3 with the attached SP-2A to SP-4A.

Addendum No. 2 F&D WWTP Raw Water Valve November 25, 2025